

CHANGXING JINGWEI BAMBOO PRODUCTS CO.,LTD
 HUAIKAN TOWNSHIP,CHANGXING COUNTY,HUZHOU CITY,ZHEJIANG PROVINCE,CHINA

The following sample(s) was / were submitted and identified on behalf of the client as:

Sample Description : ENGINEERED RIGID CORE TIMBER FLOOR
 Sample Receiving Date : Aug.08, 2019
 Test Performing Date : Aug.12, 2019 to Aug.23, 2019

Test Result Summary

No.	Test item	Test(s) Requested(Method)	Result(s)	Comments
1	Swelling and water absorption	EN 15534-1:2014+A1:2007 Clause 8.3.1 & EN 317-1993	Refer to next page(s)	/

For further details, please refer to the following page(s)

Signed for and on behalf of
 Shunde Branch
 SGS-CSTC Co., Ltd.




Peter Zhao
 Approved signatory



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

1/F, 1st Building European Industrial Park, No.1 Shunhe South Road, Wusha Section, Daikang Town, Shunde, Foshan, Guangdong, China 528333 t (86-757)22805888 f (86-757)22805858 www.sgs.com.cn
 中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号厂房首层 邮编: 528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

Test Information:

Sample description: See photo

1. Test item: Swelling and water absorption

Test method: EN 15534-1:2014+A1:2007 Clause 8.3.1 & EN 317-1993


Test condition:

(20±2) °C cold water immersion, 48h

Test result:

Sample	Test results		Conclusion
A	Water absorption	0.2%	
	Swelling	length	0.1%
		width	0%
		thickness	0%
			/

Photo Appendix:



End of Report



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com